

1   **Expert Evidence in New Brunswick's Energy and Utilities Board (EUB)**  
2   **Matter EL-002-2025**

3   January 2026

6   **Introduction and Purpose:**

7   1. Please state your name, occupation, business address, and the nature of your  
8   business.  
9      a. Toby D. Couture, Founder and Director of E3 Analytics, Blücherstr. 55,  
10   10961, Berlin, Germany

12   I am an energy and financial analyst and provide advice to governments,  
13   utilities, and regulatory agencies focusing on a range of energy sector topics,  
14   with a strong focus on the power sector and power sector transformation. E3  
15   Analytics is an independent energy consulting firm based in Berlin, Germany.  
16   It has no relation to other companies or consultancies that share the terms  
17   “E3”, including “E3G”, “E3”, and others. For more information, see:  
18   <https://www.e3analytics.eu/>

20   2. On whose behalf are you testifying in this proceeding?  
21      a. I am testifying on behalf of the Conservation Council of New Brunswick  
22   (CCNB).

24   3. Please describe your professional and academic background and your field(s) of  
25   expertise.  
26      a. I have been working in the energy sector for 20 years and have advised  
27   governments and senior government officials in over fifty (50) countries  
28   worldwide, including in Europe, Asia, the Middle East, Pacific Island states,  
29   Africa, and the Americas. I have a Master's of Science (MSc.) in Financial and  
30   Commercial Regulation from the London School of Economics in the UK, as  
31   well as an MA from the Université de Moncton where I focused on wind  
32   power policy and financing models, and a BA First Class Honors from Mount  
33   Allison University in New Brunswick. I am a Fulbright Scholar, and have  
34   worked previously at the National Renewable Energy Laboratory (NREL) in  
35   the United States, the Department of Energy's foremost research lab  
36   focused on renewable energy technology and policy.

38   4. Have you previously testified before regulatory commissions or courts on matters  
39   within your field(s) of expertise?  
40      a. Yes. I have previously testified before the Utilities and Review Board (UARB)  
41   in Nova Scotia (NSUARB-BRD-E-R-10, IN THE MATTER OF: Renewable Energy  
42   Regulations under the *Electricity Act*, R.S.N.S. 2004, c. 25, s. 1, as amended -  
43   and- IN THE MATTER OF: Renewable Energy Community Feed-In Tariffs) as

1 well as before the Energy Resources Conservation and Development  
2 Commission of the State of California (Docket 09-IEP-1G relating to the  
3 implementation of the State's Renewables Portfolio Standard)

4

5

6 5. Please describe the nature of the expertise you have previously provided as an  
7 expert witness.

8 a. I have provided expert witness testimony and evidence in matters relating to  
9 energy policy, tariff setting, and renewable energy deployment. I have also  
10 acted as an expert advisor to a range of governments on renewable energy  
11 technology costs as well as battery storage costs, including to the  
12 Governments of Vietnam, India, Indonesia, Lesotho, Brazil, and others.

13

14

15 **Summary of Testimony:**

16 Renewables backed by storage can deliver low-cost, and more reliable energy and  
17 capacity to NB's power system than the proposed dual-fuel plant.

18

19 As both gas plant and fuel supply costs have continued to rise in recent years, and the  
20 costs of alternatives like renewables and storage have continued to decline, the  
21 economics across the power sector increasingly favor renewables backed by storage.

22

23 Concerns around the inability of renewables and storage to meet adequacy requirements  
24 are unfounded.

25

26

27

28

29

30

31

1      **Expert Submission**

2

3      **1. Please provide your knowledge of the current costs of using battery**  
4      **storage to provide electricity system capacity, including in Canada.**

5

6      **Global Costs:**

7      In 2025, the global average price of a turnkey battery energy storage system (BESS) is  
8      C\$161/kWh,<sup>1</sup> according to the Energy Storage Systems Cost Survey 2025 from  
9      BloombergNEF (BNEF), published December 10<sup>th</sup> 2025.<sup>2</sup> BNEF collected system costs and  
10     project data from 596 unique submissions, finding global averages for 2-hour duration  
11     systems at C\$171/kWh and C\$151/kWh for 4-hour duration systems.

12

13     These findings are corroborated by the International Renewable Energy Agency's recent  
14     cost report.<sup>3</sup> According to IRENA, costs for BESS systems have declined by 93% between  
15     2010 and 2024. In particular utility-scale BESS costs have declined by an average of 38%  
16     for 2-hour systems and 32% for 4-hour systems between 2023 and 2024.

17

18     Turning to 2025 cost declines, the observed average decline in utility-scale BESS systems  
19     in 2024-2025 is estimated at Ember at 31%, adjusting for inflation. Taken together, this  
20     translates into a 59% decline between average utility-scale BESS costs in 2023 and in 2025  
21     (namely, a decline from C\$388/kWh to C\$161/kWh).<sup>4</sup>

22

23     This significant and continued decline in BESS costs is being driven by several factors:

- 24      • **Falling material prices** (particularly lithium prices).
- 25      • **Increased competition:** Intense competition over market share, particularly  
26         among manufacturers in China.
- 27      • **Manufacturing scale-up:** The rapid scale-up of assembly plants has led to greater  
28         efficiency and greater economies of scale.
- 29      • **Technological advancements:** The industry shift toward lower-cost Lithium Iron  
30         Phosphate (LFP) chemistries and larger cell sizes has helped further drive cost  
31         reductions.

32

33     This notwithstanding, it is important to note that country-specific costs often differ.  
34     Regional differences persist due to local supply chain related factors, import duties, taxes,

---

<sup>1</sup> Note : all currency conversions have been updated to January 2026, and have been converted using [www.xe.com](http://www.xe.com)

<sup>2</sup> Energy Storage News (2025a). <https://www.energy-storage.news/battery-storage-system-prices-continue-to-fall-sharply-bnef-and-ember-reports-find/>

<sup>3</sup> IRENA (2025). <https://www.irena.org/News/articles/2025/Aug/Battery-energy-storage-systems-key-to-renewable-power-supply-demand-gaps>

<sup>4</sup> Energy Storage News (2025a). <https://www.energy-storage.news/battery-storage-system-prices-continue-to-fall-sharply-bnef-and-ember-reports-find/>

1 and other factors. Prices in China, for instance, remain well-below the global average of  
2 C\$161/kWh at approximately C\$100/kWh in 2025.

3  
4 The cost of grid connection can also vary widely, with grid connection fees ranging from  
5 C\$40/kWh in some cases to C\$130/kWh in others.

6  
7 In addition, larger battery cells have contributed to lower unit costs overall. In 2025, DC-  
8 side systems that used 300Ah or larger cells were found to be 50% cheaper than systems  
9 with smaller cells. At the container level, larger DC blocks with 4MWh capacity or more  
10 were found to be 39% cheaper than configurations between 2MWh and 4MWh in size.  
11 These developments underscore the enduring impact of economies of scale on the rapidly  
12 changing BESS industry landscape.

13  
14 **Canada-specific costs:**

15 Evidence from recently constructed BESS projects within Canada indicates that costs  
16 remain markedly higher than in some of the more mature global markets with larger market  
17 sizes (see Table 1). The table below provides an overview of some of the recent utility-scale  
18 BESS projects currently under construction or recently completed in Canada.

19

Project Name	Location	Expected entry into commercial operation	Capacity	Total Project Cost in \$C Million Cost in \$/MWh
Jurassic BESS Project	Alberta, Canada	Late 2026	80 MW / 160MWh (2-hour) battery	120 C\$ Million 750 C\$/kWh
Skyview 2 BESS	Ontario, Canada	Q2 2027	390 MW / 1560 MWh (4-hour) battery	750 C\$ Million 480 C\$/kWh
Hagersville BESS	Ontario, Canada	Q4 2025	300 MW / 1200 MWh (4-hour) battery	538 C\$ Million 448 C\$/kWh
Oneida BESS Project	Ontario, Canada	May 2025	250MW / 1000 MWh (4-hour) battery	700 C\$ Million 700 C\$/kWh

20

1 **Table 1: Overview of recent utility-scale BESS projects in Canada**

2 Sources:

3 Jurassic BESS Project: Northland Power (2025).

4 <https://www.northlandpower.com/en/news/press-release/northland-power-secures-financing-to-advance-the-jurassic-battery-energy-storage-project-in-alberta.aspx>

5 Skyview 2 Project: Power and Telecom (2025).

6 <https://powerandtelecom.ca/projects/skyview-2-battery-energy-storage-project-secures-contract-with-ieso/>

7 Hagersville BESS Project: Energy Storage News (2024). <https://www.ess-news.com/2024/12/18/hagersville-battery-park-energy-storage-canada-financing/>

8 Oneida BESS Project: Northland Power (2023).

9 <https://www.northlandpower.com/en/news/press-release/northland-power-announces-commercial-operations-at-oneida-energy-storage-project-canadas-largest-bat.aspx#:~:text=The%20project%20was%20completed%20with,at%20financial%20close%20in%202023.>

10 As the table above shows, the cost differential is significant, and ranges from 2-3 times  
11 global averages reported by BNEF, IRENA, and Ember. Such a large cost differential is  
12 difficult to account for on the basis of small market size alone. There are several reasons  
13 why the costs in Canada might be higher than in other global or regional markets and that  
14 may account (in part or in full) for the observed disparity:

15

16

17

18

19

20

21

22

- Canada continues to apply import tariffs, particularly on the lowest-cost sources of BESS-related components (which are often from China, which remains the global hub of BESS supply chains);<sup>5</sup>
- Some jurisdictions within Canada have introduced a range of ways to favor local producers and local manufacturers of batteries and battery-related equipment;<sup>6</sup>
- Projects financed in Canada typically have a slightly higher cost of capital than projects built in the EU, or the US, which tends to push up overall project costs.<sup>7</sup>
- And finally, it is possible that BESS project costs are somewhat higher due to the more stringent requirements for black-start capability and other ancillary services from the IESO (Ontario)<sup>8</sup> and the AESO (Alberta)<sup>9</sup> in particular.

---

<sup>5</sup> Global Affairs Canada (2025). <https://international.canada.ca/en/global-affairs/corporate/transparency/briefing-documents/parliamentary-committee/2024-10-21-ciit> and Lashitew, A (2025). <https://news.mcmaster.ca/analysis-canadas-tariff-wall-on-chinese-electric-vehicles-is-deepening-dependence-on-the-u-s/>

<sup>6</sup> Energy Storage News (March 18 2025). <https://www.energy-storage.news/the-more-local-we-produce-the-better-evlo-on-tariffs/>

<sup>7</sup> RSM Canada (December 10 2024). <https://rsmcanada.com/insights/economics/canadian-firms-in-an-era-of-a-higher-cost-of-capital.html>

<sup>8</sup> IESO (2025). Ancillary Services, <https://www.ieso.ca/ancillary-services#:~:text=Certified%20black%20start%20facilities%20help%20system%20reliability,re%2Denergize%20the%20portions%20of%20the%20power%20system.>

<sup>9</sup> AESO (2025). <https://aesoenengage.aeso.ca/black-start-services-nw-procurement>

1 Taken together, these factors likely contribute to pushing costs up for projects built in  
2 Canada versus other markets. By extension, this would be likely to be relevant for BESS  
3 projects planned or constructed in New Brunswick.

4  
5 However, it is important to underscore that NB Power as well as the government of New  
6 Brunswick have tools at their disposal to help reduce this cost premium, specifically with  
7 regard to grid integration requirements, ancillary services requirements, and local  
8 construction costs. In its procurement processes, NB Power could also demonstrate its  
9 commitment to avoiding gold plating by ensuring that project design and interconnection  
10 requirements are aligned with international best practices. Further, making land available  
11 (e.g. Crown land) at a reduced cost (or leasing it) and streamlining approval procedures is a  
12 common strategy used elsewhere to further help reduce project costs,<sup>10</sup> which may help to  
13 close the gap with international benchmarks.

14  
15 In addition, recent BESS projects built elsewhere in Canada have benefited from  
16 government support, including through the "Smart Renewables and Electrification  
17 Pathways" program which extends through 2036.<sup>11</sup> Financial incentives are also available  
18 through a federal Clean Technology Investment Tax Credit which is expected to extend  
19 through 2034.<sup>12</sup> Such policies and support programs could help further bring costs down.

20  
21

22 **2. Evidence filed by NB Power in this proceeding indicates that NB Power  
23 should secure 400 MW of capacity by 2028 in order to maintain resource  
24 adequacy and ensure system reliability. NB Power asserts that using  
25 battery storage to meet this 400 MW capacity requirement would be far  
26 more expensive than using combustion turbines (see section 3.2.2 of NB  
27 Power's evidence). What is your opinion of NB Power's evidence  
28 concerning the costs of using battery storage to provide electricity  
29 system capacity?**

30 NB Power appears to be using outdated numbers and assumptions to make its case. NB  
31 Power claims that battery storage would be more expensive than the proposed RIGS plant.  
32 To justify this, it refers to a tender held in 2023. However, as highlighted above, global BESS  
33 costs have decreased by 59% since 2023 and continue to decline.

34

---

<sup>10</sup> See : Sim, L., Young, K. E. (2025). What impedes solar energy deployment? New evidence from power developers in the Arab Gulf States, *Energy for Sustainable Development*, Vol. 84, <https://doi.org/10.1016/j.esd.2024.101597>.  
<https://www.sciencedirect.com/science/article/pii/S0973082624002230>

<sup>11</sup> Natural Resources Canada (2025). <https://natural-resources.ca/climate-change/sreps>


<sup>12</sup> Government of Canada (2025). <https://www.canada.ca/en/revenue-agency/services/tax/businesses/topics/corporations/business-tax-credits/clean-economy-itc/clean-technology-itc.html>

1 According to a recent analysis from the Energy Transitions Commission (a UK-based  
2 research body established by the UK Government), battery storage prices are expected to  
3 halve again by 2035.<sup>13</sup>

4  
5 Taken together, this suggests that a Request for Proposals launched in 2026 for plant  
6 construction in 2027 would yield substantially lower bid prices than bids submitted in  
7 2023. In short, bid prices from 2023 are neither an accurate nor a reliable basis for  
8 determining the cost-competitiveness of different options in the 2026-2028 timeframe,  
9 given the rapid pace of change in the global and regional power sector.

10  
11 The chart below (Figure 1) provides a range of generation and storage options drawing on  
12 data and sources from 2024 and 2025.

13



14  
15 **Figure 1: Levelized cost of energy (LCOE) comparison for utility-scale projects across**  
16 **generation technologies, in C\$/kWh**

17 Sources:

18 CSIRO Gencost:

19 [GenCost: cost of building Australia's future electricity needs - CSIRO](https://www.csiro.au/en/research/energy/energy-systems/energy-economics/gen-cost-cost-of-building-australias-future-electricity-needs)

20 Lazard - LCOE+ 2025

21 <https://www.lazard.com/media/5tlbhyla/lazards-lcoeplus-june-2025- vf.pdf>

22 Clean Energy Canada

23 [A Renewables Powerhouse - Clean Energy Canada](https://cleanenergycanada.ca/renewables-powerhouse)

13 Source: ETC (2025). [https://www.energy-transitions.org/wp-content/uploads/2025/07/Power-Systems-Transformation\\_Main-report\\_vf.pdf](https://www.energy-transitions.org/wp-content/uploads/2025/07/Power-Systems-Transformation_Main-report_vf.pdf)

1 NREL (2025). Annual Technology Baseline,  
2 <https://atb.nrel.gov/electricity/2024/technologies>  
3 Ember  
4 <https://ember-energy.org/latest-insights/how-cheap-is-battery-storage/#3-with-a-65-mwh-lcos-shifting-half-of-daily-solar->  
5  
6  
7  
8 In terms of the leveled cost of capacity (\$/kW-month or \$/kW-year), this is a less widely  
9 used metric, as what keeps the lights on is ultimately useful energy, not capacity.  
10 Capacity-based metrics can also be misleading, particularly for plants whose costs are  
11 mainly driven by fuel costs. See table 2.  
12

### **Applying the Levelized Cost of Capacity Metric**

On a capacity basis (\$/kW-month), a back-up diesel generator for one's home may seem like good value for money.

Assuming an 8kW diesel generator costs C\$ 8,000, lasts for 15 years, and is never used, it would have a leveled cost of capacity of C\$ 4.40/kW-month. However, this is misleading, as it ignores how expensive it is to operate.

At current diesel prices of C\$ 1.69/L in New Brunswick, and a consumption rate of roughly 3L/hour at full output, this works out to C\$ 5.07/hour to produce 8kWh of electricity. Leaving aside conversion losses, this results in a fuel-only generation cost of \$0.63/kWh. The more the diesel generator is operated, the higher the real cost to the user.

This illustrates why the leveled cost of capacity is a misleading metric, and why it is more common to use the leveled cost of energy (LCOE) as a basis for comparison, particularly for plants whose operating costs are highly dependent on fuel prices.

Source for NB diesel prices: <https://www.ctvnews.ca/atlantic/article/no-change-in-nova-scotia-pei-gas-prices/>

### **Table 2: Applying the Levelized Cost of Capacity (LCOC) Metric**

In Lazard's latest Levelized Cost of Storage analysis (v.10 from June 2025), it includes the leveled cost of storage expressed in \$/kW-year. Converting to months, the values for both 2-hr and 4-hr batteries are provided below.

	<b>Levelized cost of capacity (USD \$/kW-month)</b>	<b>Levelized cost of capacity (C \$/kW-month)</b>
Utility-Scale BESS (100MW, 2-hr)	6.75 – 14.50	9.37 – 20.13
Utility-Scale BESS (100MW, 4-hr)	12.08 – 26.58	16.77 – 36.90

1 **Table 3: Summary of the Levelized Cost of Capacity**

2 **Source:** Lazard (June 2025). <https://www.lazard.com/media/5tlbhyla/lazards-lcoeplus-june-2025-vf.pdf>

3 USD : CAD = 1.3886 (January 8 2026), xe.com

4  
5  
6 It is noteworthy that the values included here in Table 3 (namely, of C\$9-37/kW-month)  
7 remain in-line with the numbers put forward by NB Power's own IRP (between C\$ 19-  
8 38/kW-month).

9  
10 Returning to a more common benchmark, LCOE (in the case of storage, the Levelized Cost  
11 of Storage (LCOS), Table 4 below provides a separate comparison of the LCOS drawing on  
12 a wider range of sources.

13

LCOS (US\$/MWh)	Converted to C\$/MWh*	Notes	Source (see References)
65	90	Global	Ember (2025)
115 - 254	160 – 352	Global (100 MW, 4-Hour)	Lazard (2025)
100	138	Global	Wood Mackenzie (2025)
93	128	Global (4-hr systems)	BNEF (2025b)
126	174	US	US Energy Information Administration (2025).

14 **Table 4: Summary of the Levelized Cost of Storage (2025)**

15  
16 Table 5 below features the costs put forward in NB Power's own Integrated Resource Plan  
17 (IRP) in 2023, both in LCOE terms and in terms of the leveled cost of capacity (see Table  
18 5).

19

Technology	Levelized Cost of Energy – Total (C\$/MWh)	Levelized Cost of Capacity (\$/kW-month)
Solar – Utility-scale	80	111
Onshore Wind	47	93
Offshore Wind	102	222
Wave	704	267
Tidal	502	191
New Biomass Boiler	294	59

Geothermal	111	77
Gas – Combined Cycle Gas Turbine	118	13
Combustion Turbine – Dual-fuel	418	9
Combustion Turbine – Gas	389	8
Combustion Turbine - Hydrogen	909	23
Lithium-Ion Battery (1-hour)	248	19
Lithium-Ion Battery (4-hour)	193	20
Lithium-Ion Battery (12-hour)	195	38
Belledune Biomass Conversion	179	7
Bayside Gas Turbine Extension	253	3

**Table 5: Levelized Cost of Energy and Capacity according to NB Power's 2023 IRP**

Source: NB Power (2023). Integrated Resource Plan,

<https://www.nbpower.com/media/1492472/2023-integrated-resource-plan-en.pdf>

Given that four of the five main sources above indicate a Levelized Cost of Storage of between C\$90 – C\$174 in 2025 (see Table 4), and that the levelized costs outlined in NB Power's 2023 IRP are estimated to be between C\$389/MWh (gas-only) and C\$418/MWh (dual-fuel), it is difficult to conclude that the proposed RIGS dual-fuel plant is more economically competitive than renewables backed by storage.

**3. In your opinion, could battery storage be deployed in New Brunswick by 2028 to meet the 400 MW capacity need identified by NB Power, whether alone or in combination with demand response programs and strategic integration of renewables?**

In its submission, NB Power suggests that any alternative other than the proposed dual-fuel plant would be impossible to deliver on this timeframe. This position is not substantiated by any evidence, nor do the examples of other jurisdictions provide grounds to suggest that the required volume of capacity (or more) could not be delivered by 2028.

It is well-known across the industry that solar, wind and storage technologies offer significant advantages in terms of construction and deployment speed. They also experience among the lowest cost-overruns (see Table 6).

## How Big Projects Performed

Source: Flyvbjerg Database

Project type	Mean cost overrun (%)	Projects (A) with $\geq 50\%$ overruns (%)	Mean overruns of A projects (%)
Nuclear storage	238	48	427
Olympic Games	157	76	200
Nuclear power	120	55	204
Hydroelectric dams	75	37	186
IT	73	18	447
Nonhydroelectric dams	71	33	202
Buildings	62	39	206
Aerospace	60	42	119
Defence	53	21	253
Bus rapid transit	40	43	69
Rail	39	28	116
Airports	39	43	88
Tunnels	37	28	103
Oil and gas	34	19	121
Ports	32	17	183
Hospitals, health	29	13	167
Mining	27	17	129
Bridges	26	21	107
Water	20	13	124
Fossil thermal power	16	14	109
Roads	16	11	102
Pipelines	14	9	110
Wind power	13	7	97
Energy transmission	8	4	166
Solar power	1	2	50

**Table 6: Mean cost-overrun for major projects**

Source: Flyvbjerg, B., cited in Engineering News Record (2023).

<https://www.enr.com/articles/55774-oxford-professors-latest-book-examines-roots-of-project-failure>

Battery storage benefits further from the development of modular, containerized designs that enable staged deployment and rapid scaling. Industry analysis confirms that batteries are more straightforward to deploy than traditional generation assets, with lower construction risk and greater timeline certainty.<sup>14</sup> This flexibility and modularity means that renewables backed by storage can add firm power capacity more rapidly than other options.

The UK's storage strategy envisions the country adding 23-27GW of shorter duration energy storage by 2030, plus an additional 4-6GW of long-duration energy storage, up from

<sup>14</sup> PV Magazine (2026). <https://www.pv-magazine.com/2026/01/02/battery-technology-outlook-for-2026-sharpens-beyond-lithium-ion/>

1 roughly 6.9GW today.<sup>15</sup> This represents annual BESS deployments of roughly 5-7GW per  
2 year, and on current trajectories, with a BESS project pipeline of 83GW currently waiting in  
3 the connection queue, the UK appears on track to achieve its objectives.

4  
5 Ontario's Independent Electricity System Operator (IESO) states that "By 2028, Ontario's  
6 entire battery storage fleet is expected to consist of 26 facilities with total capacity of 2,916  
7 MW."<sup>16</sup> This would represent a nearly 7-fold increase from its total current installed BESS  
8 capacity of 430MW and suggests annual deployments in each of the coming years (2025-  
9 2028) of over 600MW. The IESO signals that this BESS capacity is specifically intended to  
10 meet the province's resource adequacy requirements.

11  
12 Massachusetts (US) plans to bring on 5GW of BESS capacity by 2030, including 3500MW of  
13 shorter duration storage (four- to ten hours), totaling 14 GWh to 35 GWh.<sup>17</sup> An additional  
14 750 MW targets long-duration storage (10- to 24-hour), and another 750 MW requires  
15 capacities exceeding 24 hours. This represents annual deployments of roughly 1GW per  
16 year.

17  
18 Battery storage assets are available on a containerized basis on project timelines as short  
19 as 3-6 months.<sup>18</sup> Larger-scale BESS projects on the order of 400MW/1600MWh are  
20 currently being built across North America within 10-18 months.<sup>19</sup>

21  
22 In light of these examples, it is difficult to conclude that achieving BESS capacity in the  
23 range of 400-800MW in New Brunswick by 2028 would be unachievable on this timeframe.

24  
25 **What about solar PV?**

26 Solar PV is now recognized as the fastest growing source of new power generation  
27 worldwide, both in absolute terms (overall global deployment), as well as on a project-by-  
28 project basis.<sup>20</sup> Recent research on project timelines shows that the bulk of utility-scale  
29 projects worldwide are built between 6-18 months.<sup>21</sup>

---

<sup>15</sup> UK Government (2025). Clean Power 2030 Action Plan, <https://assets.publishing.service.gov.uk/media/677bc80399c93b7286a396d6/clean-power-2030-action-plan-main-report.pdf>

<sup>16</sup> IESO (2024). <https://www.ieso.ca/-/media/Files/IESO/Document-Library/resource-adequacy/ieso-resource-adequacy-update-May2024.pdf>

<sup>17</sup> ESS Storage News (2025). <https://www.ess-news.com/2025/06/18/us-tender-alert-massachusetts-takes-steps-toward-40-gwh-energy-storage/>

<sup>18</sup> Wärtsila (2026). <https://www.wartsila.com/energy/energy-storage/technology/quantum-bess>

<sup>19</sup> ESS Storage News (2024). <https://www.ess-news.com/2024/12/18/hagersville-battery-park-energy-storage-canada-financing/>

<sup>20</sup> IEA (2025). <https://www.iea.org/reports/renewables-2025>

<sup>21</sup> Gumber, A., Zana, R., Steffen, B., (2024). A global analysis of renewable energy project commissioning timelines, Applied Energy, Volume 358, <https://doi.org/10.1016/j.apenergy.2023.122563>  
<https://www.sciencedirect.com/science/article/pii/S030626192301927X>

1 In both 2024 and 2025, over 500GW of solar PV capacity have been added worldwide,  
2 which represents a daily deployment level of over 1.5GW per day. Globally, the world now  
3 has nearly 3TW of installed solar PV capacity representing approximately 20% of the global  
4 installed power generation capacity.

5  
6 Markets like Germany have been installing over 1GW per month every month for several  
7 years in a row. Smaller jurisdictions in North America like Vermont now have over 450MW  
8 of solar PV capacity installed,<sup>22</sup> and are adding over 50MW per year, while neighboring  
9 Maine has a total of 1,862MW installed as of Q3:2025.<sup>23</sup> Both Vermont and Maine meet  
10 roughly 17% of their annual power demand from solar PV today.

11  
12 By comparison to both global and North American trends, New Brunswick is lagging  
13 behind, with total utility-scale solar deployment to date of only 1.6MW. While a further  
14 10MW is under construction near Saint John and expected to enter into commercial  
15 operation in 2026, this still leaves New Brunswick with per capita solar PV capacity of  
16 around 13W compared to a per capita installed solar capacity of 694W in Vermont, and  
17 1,330W/capita in neighboring Maine.

18  
19 In sum, NB Power has not provided evidence demonstrating that renewables backed by  
20 storage could not provide the required firm capacity on time. Evidence from international  
21 and North American cases, as well as from projects in other jurisdictions within Canada,  
22 suggest that there is no reason to believe it could not do so.

23  
24  
**25 4. NB Power's evidence in this proceeding describes potential shortcomings  
26 of using battery storage to meet the 400 MW capacity requirement that  
27 NB Power has identified, including the possibility that a generation  
28 outage might occur while a battery was depleted and the possibility that  
29 the system could require energy for more hours than a battery can  
30 provide (see section 3.2.2 of NB Power's evidence). What is your opinion  
31 of NB Power's representation of these potential shortcomings?**

32  
33 The primary driver for the proposed RIGS plant according to NB Power's submission is the  
34 need for new firm capacity to meet the province's resource adequacy requirements. The  
35 peak demand period that occurred in the winter of 2023 during which neighboring

---

<sup>22</sup> Vermont Legislative Services Committee (2025). <https://www.uvm.edu/d10-files/documents/2025-12/Financial-Features-of-Large-Scale-Solar-Array-Projects-in-Vermont.pdf>

<sup>23</sup> SEIA (2025). <https://seia.org/state-solar-policy/maine-solar/#:~:text=According%20to%20the%20SEIA%2C%20Maine%20has%20the,SEIA%20also%20has%20a%20National%20Solar%20Database>

1 suppliers were unable to provide additional power supply on request, put considerable  
2 strain on NB Power’s system, and has fueled concerns that the utility may be unable to  
3 maintain reliable power system operation if such a confluence of circumstances were to  
4 occur again in the future.

5  
6 As battery storage spreads and starts to play an increasingly important role in supporting  
7 the grid and in providing ancillary services, the legal and regulatory obligations imposed on  
8 BESS plant operators are growing. In certain cases, regulators have begun introducing  
9 penalties on BESS operators for failing to maintain charge levels sufficient to provide the  
10 ancillary services for which they are compensated.

11  
12 In California, the California Public Utilities Commission (CPUC) has expanded General  
13 Order 167-C to include BESS assets.<sup>24</sup> The Order requires BESS projects larger than 50MW  
14 to maintain accurate logbooks of charging and discharging and operators can face fines for  
15 non-compliance. In parallel, CAISO is implementing new “state-of-charge” management  
16 requirements to ensure that BESS assets can reliably and consistently meet their bid  
17 obligations.<sup>25</sup> These orders currently apply mainly to ancillary services provision and are  
18 designed to ensure that BESS assets retain sufficient charge to meet the grid’s ancillary  
19 services needs, including system reliability and adequacy requirements. Similar “state-of-  
20 charge” requirements have also been implemented by NYISO.<sup>26</sup>

21  
22 In New Brunswick’s case, the addition of BESS assets could be accompanied by state-of-  
23 charge requirements, particularly during the winter months when system needs are likely  
24 to be higher. While such a regulatory approach limits operator flexibility, it has the  
25 advantage of ensuring that BESS assets retain the levels of charge needed to support the  
26 system. In the absence of a formal rule or regulation, such requirements could also be  
27 incorporated directly into individual BESS contracts.

28  
29 This notwithstanding, concerns may remain that in order to maintain their required level of  
30 charge, BESS assets would be placing strain on the grid. This is one reason why a growing  
31 number of BESS projects are co-sited with a nearby renewable energy project.

32  
33 NB Power’s highest peak demand was reached in February 2023 at just under 3,100MW.

---

<sup>24</sup> Sidley (2025). [https://www.sidley.com/-/media/publications/california-approves-major-overhaul-of-battery-storage-om-standards.pdf%3Frev=752c6d3c03fa414e88a940a70a13fafa&sc\\_lang=en](https://www.sidley.com/-/media/publications/california-approves-major-overhaul-of-battery-storage-om-standards.pdf%3Frev=752c6d3c03fa414e88a940a70a13fafa&sc_lang=en)

<sup>25</sup> Modo Energy (2025a). <https://modoenergy.com/research/caiso-five-key-policy-market-design-initiatives-follow-2025-stakeholder-process-timeline-impact-battery-energy-storage>

<sup>26</sup> Modo Energy (2025b). <https://modoenergy.com/research/en/nyiso-ancillary-service-beginners-guide-to-operations-battery-energy-storage-frequency-regulation-reserves>

1 A newly-built renewables + storage system would not, however, have to meet or replace **all**  
2 of NB Power's 3100MW of peak demand requirements. The proposed 400MW RIGS plant  
3 would not accomplish this either. What is in question is the need to provide additional  
4 capacity to the system, enabling NB Power to go from for instance, 2800MW of available  
5 power generation capacity to as high as, e.g., 3200MW, to reliably and adequately supply  
6 peak demand, should peak demand rise again to 3,100MW or beyond. This is the use case  
7 being discussed, and the use case for which the RIGS plant in question is being proposed.  
8

9 If the BESS system needs to recharged using available power generation within the system,  
10 or from power imported from either Nova Scotia, PEI, Maine, or Hydro Quebec, this would  
11 still represent power that could be otherwise used to directly supply electricity demand in  
12 New Brunswick. Seen from this perspective, the presence of a new BESS system charging  
13 from the grid could be seen to be competing with NB Power for kWh.

14  
15 While this competition with NB Power's own power supply needs would not pose a  
16 problem during normal operating hours (for instance, during off-peak or even shoulder  
17 periods), it could pose a potential conflict during critical peak times.  
18

19 In order to avoid this scenario, most utility-scale BESS systems being built both in North  
20 America and worldwide adopt one of two approaches:

- 21 1. either they are co-sited with a nearby renewable energy project, such as a solar  
22 project or a wind farm; or
- 23 2. they sign an agreement with a third-party player who owns such an asset (or a fund  
24 or aggregator that owns a portfolio of such assets) for the power supply needed to  
25 charge the battery, either directly from an adjacent site, or via a wheeling or “direct  
26 power purchase” agreement.

27  
28 In order to avoid potential conflicts with NB Power's own supply needs during critical peak  
29 periods, a utility-scale BESS system could be coupled either to a nearby wind farm, to a  
30 utility-scale solar PV project, or both, in order to enable the batteries to be charged from  
31 nearby renewable electricity supply without coming into conflict with NB Power's own  
32 power supply needs. To avoid creating, or exacerbating, local congestion issues in the grid,  
33 co-location is becoming the most common approach.  
34

35 Despite the presence of shorter winter days (and sunlight hours), a co-sited BESS system  
36 located near a utility-scale solar PV project could be charged during the daytime using the  
37 output from the nearby solar project, without putting strain on the grid. This energy could

1 then be stored to support with evening peaks, or with early morning peaks the next day, or  
2 both, depending on the operating strategy of the BESS asset.

3

4 Such a solar (and/or wind) charged BESS asset would help alleviate pressure on the grid  
5 and support New Brunswick's power reliability during critical peak demand periods.

6

7 With regard to the duration of BESS operation, the conventional wisdom is that BESS  
8 assets cannot provide firm capacity to back-up the system for more than a few hours.  
9 However, real-world experience with operating BESS systems demonstrates that by  
10 operating at less than maximum output, their power supply can be extended over a period  
11 of 8, 12, or even 24 hours or longer (see Table 7 below).

12

<b>Duration</b>	<b>Max Firm Capacity / Power Output of a 400MW/1600MWh BESS project</b>
4	400MW
8	200MW
12	133MW
16	100MW
32	50MW

13 **Table 7: Illustrative duration of 400MW/1600MWh battery asset over longer  
14 timeframes**

15  
16 While utility-scale BESS assets are often built for 4-hours of storage, this represents the  
17 storage duration at maximum power discharge. However, by adjusting the operation of the  
18 battery to system needs, the discharge rate can be spread out over time, and can be  
19 stretched to supply power for significantly longer. This flexibility enables BESS to support  
20 the grid over longer periods of time, including overnight.

21

22 NB Power's assessment of the shortcomings of renewables backed by storage do not  
23 reflect common industry practice. A host of regulatory, contractual, and operational  
24 solutions exist to address these challenges.

25

26

1       **5. Did your review of NB Power’s evidence concerning renewables**  
2       **integration, demand response programs, and battery storage**  
3       **performance identify any assumptions that you believe to be incorrect?**

4

5       There are four main areas where NB Power’s assumptions appear to deviate from current  
6       industry trends.

7

8       **The inability of RE technologies to provide capacity:**

9       NB Power writes in its submission that “*Generally, intermittent renewable generation*  
10      *sources are not considered to be significant sources of capacity.*” (page 20, lines 13-14).  
11      While this is broadly correct, it remains the case that renewables like wind and solar are  
12      attributed some capacity value, with onshore wind power often being attributed a capacity  
13      value of between 10-30%,<sup>27</sup> offshore wind between 15-40%, and solar PV between 5-25%,  
14      depending on the location, whether trackers are used in the case of solar PV, and the  
15      degree of correspondence with a jurisdiction’s demand curve.<sup>28</sup>

16

17      The most common metric used to assess the contribution of a particular resource to  
18      system capacity is the “*effective load carrying capacity*,” or ELCC. The ELCC of a  
19      generating resource is a measurement of that resource’s ability to produce electricity  
20      during periods of shortfall.

21

22      The ELCC values put forward by NB Power in its 2023 IRP are not in line with current  
23      industry realities. A related issue is that NB Power considers the resources in isolation  
24      (solar, wind, and batteries) rather than together. To gain a more accurate picture of the real  
25      ELCC of variable renewables like wind and solar combined with storage, it is common to  
26      consider the joint operation of hybrid wind, solar, and storage plants. A recent analysis  
27      from NREL concludes that the ELCC of such hybrid renewable plus storage projects can  
28      readily exceed 80% (see Table 8).<sup>29</sup>

---

<sup>27</sup> Holttinen, H., et al. (2016). Assessing capacity value of wind power, [https://iea-wind.org/wp-content/uploads/2021/08/2016\\_WIW16\\_Capacity-value\\_paper\\_final\\_web.pdf](https://iea-wind.org/wp-content/uploads/2021/08/2016_WIW16_Capacity-value_paper_final_web.pdf)

<sup>28</sup> Pham, A., Cole, W., Gagnon, P. (2024). Average and marginal capacity credit values of renewable energy and battery storage in the United States power system, NREL, <https://docs.nrel.gov/docs/fy25osti/89587.pdf>

<sup>29</sup> Ericson et al. (2022). Influence of hybridization on the capacity value of PV and battery resources, NREL, <https://docs.nrel.gov/docs/fy22osti/75864.pdf>

ELCC Class	2023	2024	2025	2026	2027	2028	2029	2030
4-hr Battery	83%	84%	77%	70%	72%	70%	69%	76%
PV hybrid loosely coupled 4-hr battery component	82%	80%	73%	65%	69%	72%	74%	87%
PV hybrid tightly coupled 4-hr battery component	82%	80%	72%	63%	69%	72%	74%	86%
PV fixed	38%	36%	32%	31%	29%	27%	25%	21%
PV tracking	54%	52%	48%	44%	42%	39%	36%	31%

**Table 8: ELCC factors from the PJM system**

Source: Ericson et al. (2022). <https://docs.nrel.gov/docs/fy22osti/75864.pdf>

Similar findings have been established showing ELCC values for BESS systems of over 80% in the Southwest Power Pool (SPP) system in the US.<sup>30</sup>

On a stand-alone basis, BESS assets consistently rank high in evaluations of ELCC.

Analysis submitted by Siemens PTI as part of recent regulatory hearings in the US State of Minnesota concludes that the ELCC values for the first 500MW of BESS in the state can achieve an ELCC of 90%.<sup>31</sup>

Recent research from the IESO in Ontario indicates a similar result, with the first 500MW block of storage capacity added yielding ELCC values of over 80%, with longer duration storage assets showing higher ELCCs than shorter duration projects.<sup>32</sup>

Similarly, in analyses prepared for the ERCOT system in Texas, the ELCC value reported for BESS assets was found to be between 74-79%.<sup>33</sup>

## Role of BESS in Supporting with Capacity and Resource Adequacy:

In recent years, the North American Electricity Reliability Council (NERC) has begun to acknowledge BESS assets as vital for resource adequacy and is in the process of establishing standards to ensure greater harmonization in capacity accreditation and the

<sup>30</sup> SPP (2023). <https://www.spp.org/documents/68930/2022%20elcc%20esr%20report.pdf>; See also: SPP (2022). <https://www.spp.org/documents/68930/2022%20elcc%20esr%20report.pdf>

<sup>31</sup> Siemens PTI (2024). <https://www.lrl.mn.gov/docs/2024/mandated/240414.pdf>


<sup>32</sup> IESO (2025). [https://www.google.com/url?sa=t&source=web&rct=j&opi=89978449&url=https://ieso.ca/-/media/Files/IESO/Document-Library/Technical-papers/ELCC-of-Energy-Storage-in-Ontario.pdf&ved=2ahUKEwiL-qTTuv6RAxWXB9sEHf\\_IibIQFn0ECB0QAQ&usg=AOvVaw30RI2GijoujXqhObb2S2g2](https://www.google.com/url?sa=t&source=web&rct=j&opi=89978449&url=https://ieso.ca/-/media/Files/IESO/Document-Library/Technical-papers/ELCC-of-Energy-Storage-in-Ontario.pdf&ved=2ahUKEwiL-qTTuv6RAxWXB9sEHf_IibIQFn0ECB0QAQ&usg=AOvVaw30RI2GijoujXqhObb2S2g2)

33 ERCOT (2024).

[https://www.google.com/url?sa=t&source=web&rct=j&opi=89978449&url=https://www.ercot.com/files/docs/2025/02/12/2024ERCOT\\_ELCC\\_Study\\_Final\\_Report02112025.pdf&ved=2ahUKEwj014mAvv6RAXUN7QIHHSWKNKIQFn\\_oECBwQAO&usg=AQyVaw3BrXT0jo5VvUmdowSMmOo1](https://www.google.com/url?sa=t&source=web&rct=j&opi=89978449&url=https://www.ercot.com/files/docs/2025/02/12/2024ERCOT_ELCC_Study_Final_Report02112025.pdf&ved=2ahUKEwj014mAvv6RAXUN7QIHHSWKNKIQFn_oECBwQAO&usg=AQyVaw3BrXT0jo5VvUmdowSMmOo1)

1 calculation of the ELCC.<sup>34</sup> These standards have converged on the so-called “rigid core,  
2 flexible edge” methodology that factors in core modelling parameters like weather,  
3 temporal and geospatial factors, which are surrounded by a set of more flexible,  
4 jurisdiction-specific parameters like energy policy and local resource characteristics (see  
5 Figure 2).

6



7  
8 **Figure 2: Overview of Rigid Core, Flexible Edge Methodology**

9 Source: NERC (2025). Evaluating Resource Contributions for Reliability and Capacity

10 Supply, [https://www.nerc.com/globalassets/our-work/reports/special-](https://www.nerc.com/globalassets/our-work/reports/special-reports/elcc_report_september_2025.pdf)

11 [reports/elcc\\_report\\_september\\_2025.pdf](https://www.nerc.com/globalassets/our-work/reports/special-reports/elcc_report_september_2025.pdf)

12  
13 Part of this methodology is intended to enable utilities and load-serving entities across  
14 North America to better evaluate the performance characteristics of co-located hybrid  
15 systems (specifically solar + storage, and wind + storage) as well as the capacity  
16 characteristics of long-duration storage options. It is also providing greater consistency in  
17 how the dispatchability and reliability contributions of demand-response resources are  
18 calculated, and attributed.

19  
20 Taken together, these undertakings by NERC are establishing BESS assets as a key  
21 resource in providing both capacity and in meeting local resource adequacy needs in the  
22 North American power system. In NERC’s latest reliability assessment for the Summer of  
23 2025, it points specifically to the role of BESS assets: “Battery resource additions are

---

<sup>34</sup> NERC (2025). Evaluating Resource Contributions for Reliability and Capacity Supply, [https://www.nerc.com/globalassets/our-work/reports/special-reports/elcc\\_report\\_september\\_2025.pdf](https://www.nerc.com/globalassets/our-work/reports/special-reports/elcc_report_september_2025.pdf)

1 helping reduce energy shortfall risks that can arise from resource variability and peaks in  
2 demand.”<sup>35</sup>

3

4 To understand the specific role that BESS assets are playing in supporting resource  
5 adequacy, it is helpful to consider the case of states with higher volumes of BESS.

6

7 In several states across the US, including in Texas, New York, Massachusetts, and  
8 California, batteries now play an important role in providing resource adequacy.

9

10 Battery storage capacity in California has grown from roughly 500 megawatts (MW) in 2020  
11 to 17,000 MW at the end of 2025, and state-level targets envision a total of 52,000MW of  
12 BESS capacity by 2045.<sup>36</sup>

13

14 The California Public Utilities Commission counts solar backed by storage toward  
15 resource adequacy obligations, now treating renewables backed by storage as  
16 dispatchable capacity.<sup>37</sup> As a result, solar backed by storage is starting to play a growing  
17 role in meeting resource adequacy needs.

18

19 A further regulatory development in California is the establishment by the California Public  
20 Utilities Commission (CPUC) of new resource adequacy rules and the creation of the 24-  
21 hour “slice-of-day” (SOD) methodology.<sup>38</sup> Under these new rules, power retailers (or load  
22 serving entities, or LSEs) need to demonstrate that they have sufficient capacity to satisfy  
23 demand for every hour on the “worst day” — the day of the month with the highest forecast  
24 peak load for the system as a whole. This means that LSEs are required to address  
25 renewable energy variability by focusing on hourly reliability, and that they need to ensure  
26 that storage assets can charge (and discharge) when needed. This obligation has led to a  
27 rapid growth in investments in BESS systems to meet this peak adequacy requirement, as  
28 well as to a greater regulatory oversight of BESS assets’ state-of-charge.

29

30 Similar examples of utilities relying on renewables backed by storage to meet adequacy  
31 requirements include Xcel Energy, a large US-based utility with operations spanning the  
32 country.

33

---

<sup>35</sup> NERC (May 2025). 2025 Summer reliability assessment,

[https://www.nerc.com/globalassets/programs/rapa/ra/nerc\\_sra\\_2025.pdf](https://www.nerc.com/globalassets/programs/rapa/ra/nerc_sra_2025.pdf)

<sup>36</sup> California Energy Commission (2025). [https://www.energy.ca.gov/news/2025-11/californias-battery-storage-fleet-continues-record-growth-strengthening-grid#:~:text=California%20has%20nearly%2017%2C000%20megawatts%20of%20battery,record%2Dbreaking%20heat%20and%20extreme%20weather%20without%20outages\\*\\*](https://www.energy.ca.gov/news/2025-11/californias-battery-storage-fleet-continues-record-growth-strengthening-grid#:~:text=California%20has%20nearly%2017%2C000%20megawatts%20of%20battery,record%2Dbreaking%20heat%20and%20extreme%20weather%20without%20outages**)

<sup>37</sup> Agarwal, P., Wooley, D. (June 2025).

[https://gspp.berkeley.edu/assets/uploads/page/Draft\\_Resource\\_Adequacy\\_Primer.pdf](https://gspp.berkeley.edu/assets/uploads/page/Draft_Resource_Adequacy_Primer.pdf)

<sup>38</sup> California Public Utilities Commission (2025). <https://www.cpuc.ca.gov/-/media/cpuc-website/divisions/energy-division/documents/resource-adequacy-homepage/resource-adequacy-compliance-materials/guides-and-resources/2026-ra-slice-of-day-filing-guide.pdf>

1 In 2023, Xcel recently launched a competitive tender for up to 800 megawatts (MW) of firm  
2 dispatchable resources in Minnesota as authorized by the Commission and envisioned in  
3 the Company's 2019 integrated resource plan (see Docket E-002/CN-23-212).<sup>39</sup> According  
4 to Xcel, firm dispatchable resources would assist the Company in meeting the utility's  
5 capacity needs. In Minnesota's case, the push is being driven by the planned phase-out of  
6 several large thermal units, including most of the remaining coal units on the Upper  
7 Midwest System.

8  
9 Initially, the utility proposed a large gas plant to meet this adequacy need. However, upon  
10 thorough examination by the Public Utilities Commission (PUC), the proposed Sherco gas  
11 plant was deemed uneconomic compared to other lower-cost resources, including  
12 renewables backed by storage (see Docket E-002/RP-19-368).<sup>40</sup>

13  
14 In reaching its decision, the Minnesota PUC summarized its conclusion as follows:

15  
16       *“...various parties and commenters argued that the record failed to demonstrate  
17 that building a combined-cycle generator at the Sherco site would be a prudent  
18 investment, and therefore ratepayers should not have to bear the cost of the plant.  
19 Ultimately Xcel withdrew its combined-cycle proposal. The Commission concurs  
20 with this choice and finds no basis in the record that would justify Xcel recovering  
21 the cost of such a project from Minnesota ratepayers.”* (p.14, E-002/RP-19-368)

22  
23  
24 **Demand forecasts:**

25 Demand growth forecasts based on growing electrification in the province do not appear  
26 sound.

27  
28 According to recent data, N.B. Power's Enhanced Energy Savings program reported 2,985  
29 homes converting from electric baseboard heaters to mini-split heat pumps in the last  
30 year. This is part of a larger trend, as overall heat pump adoption in New Brunswick has  
31 increased significantly, with a total of 12,211 heat pumps installed through the federal  
32 Greener Homes Initiative as of November 2024.<sup>41</sup> Since electric heat pumps operate more  
33 efficiently than the resistance or “baseboard” heating common in NB homes, the growing  
34 “electrification” in this sector should (ceteris paribus) serve to reduce peak demand, not

---

<sup>39</sup> Minnesota Public Utilities Commission (2023).

<https://efiling.web.commerce.state.mn.us/documents/%7BD038968B-0000-CE1E-9643-CFF068E843FA%7D/download?contentSequence=0&rowIndex=442>

<sup>40</sup> Minnesota Public Utilities Commission (2022).

<https://efiling.web.commerce.state.mn.us/documents/%7B202C2F80-0000-C11A-BA52-EC8AB5636CD4%7D/download?contentSequence=0&rowIndex=169>

<sup>41</sup> Natural Resources Canada (2025). <https://natural-resources.ca/energy-efficiency/home-energy-efficiency/canada-greener-homes-initiative/greener-homes-initiative-progress-update-november-2024>

1 increase it, as heat pumps have significantly lower peak wattage than traditional  
2 resistance heating systems.<sup>42</sup>

3  
4 A typical home equipped with either an electric furnace or with electric baseboard heaters  
5 generally requires between 10kW and 50kW of electricity depending on the size of the  
6 home; a comparable heat pump system typically uses between 3.5kW to 7 kW to provide  
7 the same amount of heat.

8  
9 The exception to this is the conversion from oil, propane, or gas heating to a heat pump: in  
10 these cases, the conversion would result in a net increase in electric demand.

11  
12 Based on StatsCan data, there were 32,500 homes relying on oil heating and 15,700 relying  
13 on natural gas in 2022, which represents roughly 14% of households in the province.<sup>43</sup>  
14 Converting the 32,500 homes currently heating with fuel oil would therefore represent an  
15 increase in peak demand of approximately 200MW (assuming 6kW heat pump systems on  
16 average). However, when conversions of homes with baseboard heating to heat pumps are  
17 factored in (which represent 133,000 homes in total), the net effect is likely to be far lower,  
18 depending on the level of uptake, and could even be netted out depending on the levels of  
19 heat pump uptake.

20  
21 With regard to electric vehicles, a halt to the federal ZEV program combined with the halt to  
22 a similar provincial program as of July 1 2025, is likely to temper EV sales growth in the  
23 province.<sup>44</sup> Stats Can reports an over 50% drop in battery electric vehicle sales nation-wide  
24 between Q3:2024 and Q3:2025.<sup>45</sup> In the absence of further policy changes on electric  
25 vehicles either at the provincial or the federal level, it is unlikely that electric vehicles will  
26 experience a substantial surge in sales on the horizon to 2027-2028.

27  
28 At the current EV market share of 7.4%, and annual new vehicle sales in the range of  
29 34,000 province-wide, this represents an annual addition of approximately 2,500 battery  
30 electric vehicles. Assuming this market share holds, and assuming annual charging-  
31 related electricity demand of approximately 5,000kWh, this represents an annual demand  
32 growth impact of 12.5 GWh per year, or less than 0.1% of NB Power's total annual  
33 electricity sales.

34

---

<sup>42</sup> See: Clean Air Alliance (2023). <https://www.cleanairalliance.org/wp-content/uploads/2023/11/Heat-Pump-Peak-Report-FINAL.pdf>. See also: BMP (2025).

<https://bpmhvac.com/home-energy/heat-pump-energy-usage-guide/#:~:text=Heat%20pumps%20typically%20use%203%2C000,system%20age%2C%20and%20usage%20habits.>

<sup>43</sup> Statistics Canada (2025a).

<https://oee.nrcan.gc.ca/corporate/statistics/neud/dpa/showTable.cfm?type=CP&sector=res&juris=nb&rn=21&year=2022&page=0>

<sup>44</sup> CBC (2025). <https://www.cbc.ca/news/canada/new-brunswick/nb-electric-vehicle-program-ends-focus-shifts-to-chargers-1.7602450>

<sup>45</sup> Statistics Canada (2025b). <https://www150.statcan.gc.ca/t1/tbl1/en/tv.action?pid=2010002501>

1 While this level of annual growth will no doubt have an impact, it is unlikely to fuel run-  
2 away growth in peak electricity demand in the coming years.  
3  
4 A further factor that counteracts NB Power’s demand growth thesis is the growing self-  
5 sufficiency of municipal utilities, most notably Saint John Energy, which is developing its  
6 own wind, solar, and battery storage projects in partnership with stakeholders with a view  
7 to reducing its own purchases from NB Power.<sup>46</sup> In fact, Saint John Energy’s latest annual  
8 reports shows that its annual purchases from NB Power have already started to decline.<sup>47</sup>  
9

10 **Demand response:**

11 With regard to demand response, NB Power appears to be underestimating the existing  
12 potential considerably. It states in its submission that it has achieved an increase in  
13 demand response of just 5MW in 2023 to 85MW in 2025, which suggests that further  
14 potential could be tapped if further effort were invested. In its summary of the remaining  
15 potential, NB Power writes that “Further growth of demand response is being considered,  
16 but the opportunity is limited by the scope of the programs.”

17  
18 In short, it appears that the demand response potential is limited by the presence of  
19 “programs” to support it – programs that NB Power itself (along with the province) is  
20 ultimately responsible for implementing (or not implementing, as the case may be).

21  
22 The example of Massachusetts demonstrates the range of what is possible to achieve in  
23 terms of reducing peak load through efficiency, demand response, and storage.<sup>48</sup>

24  
25 Demand response entails multiple different forms of intervention, including some targeting  
26 residential, commercial, industrial, and institutional electricity customers. Most utility  
27 programs to date have focused on the large “low-hanging” fruit in the industrial sector.  
28 However, as experience with demand response grows, the potential of other applications  
29 and customer types is becoming more apparent and often far outstrips the potential of  
30 industrial demand response.

31  
32 Analysis conducted for Massachusetts shows the potential for passive load management  
33 measures such as heat pumps and building insulation can reduce peak demand by 2.7 to  
34 3.7 GW by 2030. In addition, adding active load management such as smart EV charging  
35 and building load flexibility can further flatten peak demand by 300 to 800 MW by 2030.<sup>49</sup>

---

<sup>46</sup> Saint John Energy (June 17 2025). <https://sjenergy.ca/about/news/saint-john-energy-announces-provinces-largest-solar-farm> and <https://zero30.ca/projects-products/#burchill>

<sup>47</sup> Saint John Energy (2024). Annual Report 2023-2024, [https://sje-cms.s3.ca-central-1.amazonaws.com/SJE\\_Annual\\_Report\\_Spring2024\\_bf60b3c2fb.pdf](https://sje-cms.s3.ca-central-1.amazonaws.com/SJE_Annual_Report_Spring2024_bf60b3c2fb.pdf)

<sup>48</sup> Massachusetts Department of Energy (2025a). Peak Potential: Load managements for an affordable net zero, <https://www.mass.gov/info-details/peak-potential-load-management-for-an-affordable-net-zero-grid>

<sup>49</sup> Massachusetts Department of Energy (2025b). Technical potential of load management, <https://www.mass.gov/doc/e3-technical-potential-of-load-management-summary-slides/download>

1 Given Massachusetts has a population roughly 9 times larger than New Brunswick, it is  
2 reasonable to assume that there are several hundred MW of active and passive demand  
3 reduction potential remaining to be tapped. NB Power's assessment appears to ignore this  
4 potential or exhibit little interest in tapping it.

5  
6 Taken together, there are a few aspects of NB Power's submission that downplay, or ignore  
7 altogether, well-established trends and developments in other electric utilities across  
8 North America.

9  
10 **6. In your opinion, could battery storage be used to meet the 400 MW  
11 capacity need that NB Power has identified at a lower cost than that of  
12 the proposed RIGS Project, whether alone or in combination with  
13 demand response programs and strategic integration of renewables?**

14  
15 For a more detailed overview of the comparative costs of battery storage, solar, wind, and  
16 dual-fuel plants, see the response to Question 2 above.

17  
18 In short, yes, alternatives such as renewables backed by storage can deliver lower cost  
19 power than the proposed RIGS plant.

20  
21 At an estimated price tag of between C\$1.2 and 1.4 Billion, the proposed RIGS plant  
22 represents a major capital commitment. The fact that a third-party company has been  
23 identified to build the plant does not remove NB Power's financial responsibilities  
24 associated with the deal, including volume payments related to actual energy generation,  
25 capacity payments, as well as any payments awarded in relation to ancillary services.

26  
27 Based on reported installed BESS prices in Canada of around C\$450/kWh<sup>50</sup> (which remain  
28 more than double global averages, and are likely to decline in the years ahead as  
29 economies of scale continue to grow, and performance improves), a comparable financial  
30 commitment would enable the construction of a BESS asset on the order of  
31 750MW/3GWh. Such a BESS project would arguably exceed New Brunswick's storage  
32 need based on current system realities.

33  
34 Scaling down the BESS asset would enable the addition of a utility-scale solar PV project to  
35 charge the battery system, including during the winter months, without putting undue  
36 strain on the grid, or limiting NB Power's own power purchase options.

---

37  
38  
50 ESS Storage News (December 18 2024). <https://www.ess-news.com/2024/12/18/hagersville-battery-park-energy-storage-canada-financing/>

1 With the scale of capital commitment currently on the table, NB Power could procure a  
2 400MW/1600MWh BESS asset, and still have enough left over for a 400-500MW solar PV  
3 project, which would be more than sufficient to charge the battery, even during the shorter  
4 winter days. By introducing contractual requirements relating to the minimum state of  
5 charge during winter months, NB Power could meet its capacity and adequacy needs  
6 without exposing itself, and NB ratepayers, to sizeable fuel price risk.

7  
8 The cost-competitiveness of renewables backed by storage is supported by several major  
9 international reports published in recent years, including from BNEF,<sup>51</sup> NREL,<sup>52</sup> Ember<sup>53</sup>,  
10 and others,<sup>54</sup> as well as by the findings of the latest report of the UK's Energy Transitions  
11 Commission:

12  
13 *“It is technically and economically possible to manage system balancing  
14 challenges in systems with very high (e.g., 80%+) wind and solar penetration,  
15 delivering round-the-clock electricity at costs below those of today’s fossil fuel-  
16 based systems.”*<sup>55</sup>

17  
18 A further difference is that renewables and storage projects are generally less exposed to  
19 price spikes caused by geopolitical factors, as seen when Russia invaded Ukraine in the  
20 winter of 2022. Once built, renewables backed by storage provide stable, reliably priced  
21 energy and services to the power system over the lifetime of the assets.

22  
23  
24 **7. In your opinion, and based on your review of NB Power’s evidence, would  
25 the proposed RIGS Project provide any cost benefits or system capacity  
26 benefits that could not be provided by battery storage, whether alone or  
27 in combination with demand response programs and strategic  
28 integration of renewables?**

29  
30 There are two potential co-benefits that the proposed RIGS plant could bring from the  
31 perspective of energy security. However, closer inspection shows that both co-benefits  
32 can be achieved without adding a dual-fuel plant to the mix.

---

<sup>51</sup> BNEF (2025a). <https://about.bnef.com/insights/clean-energy/how-pv-plus-storage-will-compete-with-gas-generation-in-the-u-s/>

<sup>52</sup> NREL (2024). Annual Technology Baseline, <https://atb.nrel.gov/electricity/2024/technologies>

<sup>53</sup> Ember (2025). <https://ember-energy.org/latest-insights/how-cheap-is-battery-storage/#3-with-a-65-mwh-lcos-shifting-half-of-daily-solar->

<sup>54</sup> Clean Energy Council (2021). <https://cleanenergycouncil.org.au/cec/media/background/resources/battery-storage-the-new-clean-peaker-report-2021.pdf>

<sup>55</sup> Energy Transitions Commission (2025). [https://www.energy-transitions.org/wp-content/uploads/2025/07/Power-Systems-Transformation\\_Main-report\\_vf.pdf](https://www.energy-transitions.org/wp-content/uploads/2025/07/Power-Systems-Transformation_Main-report_vf.pdf)

1 First, the planned addition of a liquid fuel storage facility at the plant provides additional  
2 energy security, as liquid fuel storage provides a valuable buffer against potential future  
3 interruptions to fuel or energy supply. Most countries maintain some form of strategic oil  
4 reserve, and a growing number are now expanding their natural gas storage facilities to  
5 provide greater protection against future disruptions to fuel supply.

6  
7 To the extent that the RIGS plant features additional liquid fuel storage capacity, it can be  
8 seen to increase the province's energy security. That said, it is important to underscore  
9 that fuel storage capacity can be added on a stand-alone basis without needing to take on  
10 the substantially larger financial commitment of investing in a new power plant.

11  
12 Indeed, NB Power already owns considerable diesel and gas-fired capacity, totaling nearly  
13 2,000MW of electricity generating capacity (see Table 9).

14

Plant	Capacity (MW)	Fuel type
Courtenay Bay	160MW	Oil
Coleson Cove	972MW	Fuel Oil
Bayside	277MW	Gas
Millbank	397MW	Diesel
Sainte-Rose	99MW	Diesel
Grand Manan	29MW	Diesel
<b>Total</b>	<b>1,934MW</b>	

15 **Table 9: Overview of the main power plants operating on liquid fuels in NB Power's  
16 generation fleet**

17 Source: NB Power (2024). Annual Report 2023-2024<sup>56</sup>

18  
19 In addition, NB Power's own fuel-based generation plants are complemented by additional  
20 gas- and oil-fired capacity located at industrial facilities across the province.

21  
22 Taking a step back and considering NB Power's generation portfolio from a comparative  
23 perspective, it is not liquid fuel plants that are missing from NB Power's mix; it is rather  
24 solar power and storage that are conspicuous by their absence.

25

---

<sup>56</sup> NB Power (2024). Annual Report 2023-2024, <https://www2.gnb.ca/content/dam/gnb/Gateways/ABCs/Annual-reports1/2023-2024/NRED-NBPC-2023-2024-annual-report-E.pdf>

1 Second, the proposed RIGS plant includes the potential addition of synchronous  
2 condensers, which could add value to NB Power's system, particularly with regard to the  
3 supply of ancillary services. However, like with fuel storage, synchronous condensers can  
4 be contracted at a substantially lower cost when built as a stand-alone asset (i.e. without a  
5 gas plant).

6  
7 Synchronous condensers are large spinning devices that are used to support grid stability  
8 and provide ancillary services. Since synchronous condensers can make it easier and  
9 cheaper to integrate larger shares of wind and solar power in particular, they are becoming  
10 increasingly common in power systems around the world. In contrast to a conventional  
11 power plant, synchronous condensers can operate without needing onsite generation.

12  
13 A recent project developed in the UK is adding synchronous condensers to the grid on a  
14 stand-alone basis, without linking it to a gas plant.<sup>57</sup> In Ireland, synchronous condensers  
15 have recently been added to a large-scale BESS asset to help stabilize the grid.<sup>58</sup>

16  
17 In a similar way, adding a stand-alone synchronous condenser to support the integration of  
18 higher shares of wind and solar in NB's power grid could be done without incurring the  
19 considerable financial liability and associated fuel-price risk of contracting a dual-fuel  
20 plant.

21  
22  
23 **8. In your opinion, how do the cost risks of the proposed RIGS Project compare  
24 to the risks of battery storage, demand response, and renewables integration  
25 alternatives?**

26  
27 One of the most substantial risks stemming from the proposed project from the  
28 perspective of ratepayers relates to the associated fuel price risk. This has important  
29 implications for NB Power's efforts to increase the share of equity in its overall capital  
30 structure to 20%, as outlined in Section 68 of the Electricity Act.

31  
32 Increasing NB Power's exposure to fuel price risk creates another (potentially large)  
33 competing claim for the proceeds generated by future rate increases. Any portion of future  
34 rate increases that is used to offset rising fuel prices represents revenue that NB Power  
35 cannot use to meet its 20% equity target.


---

<sup>57</sup> Uniper (2025). <https://www.uniper.energy/news/grid-stability-technology-without-the-need-to-generate-power-comes-into-operation-at-unipers-killingholme-site>

<sup>58</sup> Siemens Energy (2025). <https://www.siemens-energy.com/global/en/home/press-releases/two-become-one-siemens-energy-combines-two-technologies-to-stab.html>

1 This becomes relevant when considering analysts' expectations with regard to future  
2 natural gas prices. According to the US National Bureau of Economic Research (NBER),  
3 natural gas prices are expected to rise in the years ahead as US exports of liquified natural  
4 gas (LNG) continue to grow (NBER 2025). This expectation is corroborated by NB Power's  
5 own estimates included in its 2023 IRP, which expects the price of gas to roughly double by  
6 the early 2040s (see Figure 3):  
7

Figure 6.2: Natural Gas Price Forecasts for Algonquin Citygate<sup>42</sup>, Dawn Hub<sup>43</sup> and AECO<sup>44</sup>



### Figure 3: Natural Gas price forecast from NB Power's IRP 2023

Source: NB Power (2023). Integrated Resource Plan,  
<https://www.nbpower.com/media/1492472/2023-integrated-resource-plan-en.pdf>

The likelihood of future price increases clearly poses a material financial and economic risk both for NB Power and its ratepayers.

These considerations notwithstanding, NB Power claims in its submission that the plant will offer "predictable operating costs": careful consideration indicates that the proposed dual-fuel plant cannot provide predictable operating costs, as a substantial portion of the plant's operating costs are not fixed, but variable, and are determined by the cost of fuel.

In other words, while the associated capacity payments stipulated in the Tolling Agreement may be predictable, the costs associated with actual electricity generation from the plant are not. For ratepayers, and the province, this remains an important risk, one that NB Power appears to downplay in its submission.

Compared to the proposed dual-fuel plant, renewables backed by storage provide stably priced electricity and ancillary services over the lifetime of the assets, without the associated fuel-price risk.

1    **9. Are there any other issues within the scope of your expertise that you would  
2    like to bring to the Board's attention in this proceeding?**

3  
4    **Challenges operating at partial load:** A further issue that merits being raised is the  
5    challenges that peaking plants like the proposed RIGS project have operating at partial  
6    load. NB Power claims that one of the functions of the proposed RIGS project is to help  
7    integrate growing shares of wind power in the province. However, peaking plants  
8    experience significant performance drops when operating at partial load:<sup>59</sup> specifically,  
9    plant efficiency declines and the emissions associated with the plant increase.

10  
11   By contrast, BESS assets operate equally efficiently at any state of charge or discharge,  
12   maintaining 95–99% efficiency regardless of output.<sup>60</sup> In the case of BESS assets, there's  
13   no performance penalty for partial load operation – in fact, batteries tend to operate more  
14   efficiently at lower discharge rates.<sup>61</sup>

15  
16   **Role of grid-forming inverters:**

17   Another area that remains undiscussed in NB Power's submission is the transformative  
18   role of **grid-forming inverters** in supporting vital grid functions. Inverters are the link  
19   between a wind, solar, or battery asset and the rest of the grid.

20  
21   Traditional so-called “grid-following” inverters follow the grid's voltage and frequency,  
22   shutting down during outages. By contrast, grid-forming inverters create their own stable  
23   voltage and frequency, enabling them to support the grid and even re-establish stability by  
24   providing virtual inertia during system disruptions.<sup>62</sup>

25  
26   As solar and wind energy start to replace traditional synchronous generators (like coal and  
27   gas plants), the grid loses part of its inertia and voltage control, which can lead to greater  
28   instability in the system. Grid-forming inverters, which are widely available on the market  
29   today and being deployed at scale in markets like the US, Australia and Europe, mimic  
30   traditional generators by providing synthetic inertia, frequency control, and voltage  
31   support, helping to keep the grid stable.

32  
33   Grid-forming inverters are becoming an increasingly important tool in power systems  
34   worldwide and could support the stability and reliability of NB Power's grid in the years  
35   ahead, particularly as ageing assets are retired.

59 Ipieca (2022). <https://www.ipieca.org/resources/energy-efficiency-compendium/open-cycle-gas-turbines-2022>

60 Redondo-Iglesias, E., Pelissier, S. (2022). On the efficiency of LFP Lithium-ion batteries,  
<https://www.researchgate.net/publication/366551786> On the Efficiency of LFP Lithium-ion Batteries

61 LFP Battery (2025). <https://www.lifepo4batteryshop.com/blogs/understanding-c-rate.html>

62 Kroposky, B. (2024). Introduction to Grid Forming Inverters, <https://docs.nrel.gov/docs/fy24osti/90256.pdf>

1   **Curtailment:** Experience from power systems that have introduced significant BESS  
2   capacity indicates that BESS systems have one important advantage that fuel-based  
3   plants do not have, namely, their dual function in helping integrate variable resources like  
4   wind and solar, and in mitigating curtailment.

5  
6   According to NB Power's 2023 IRP, curtailment already poses a significant problem under  
7   its existing contracts with independent power producers and represents an issue that is  
8   likely to grow with the addition of more wind power capacity in the coming years.<sup>63</sup> Adding  
9   battery storage would therefore carry an important co-benefit for NB Power's system: it  
10   would enable NB Power to reduce curtailment, while mitigating the losses (both electrical  
11   and financial) associated with it.

---

<sup>63</sup> NB Power (2023). Integrated Resource Plan, <https://www.nbpower.com/media/1492472/2023-integrated-resource-plan-en.pdf>

1   **References:**

2

3   AESO (2025). <https://aesengage.aeso.ca/black-start-services-nw-procurement>

4

5   Agarwal, P., Wooley, D. (June 2025).  
[https://gspp.berkeley.edu/assets/uploads/page/Draft\\_Resource\\_Adequacy\\_Primer.pdf](https://gspp.berkeley.edu/assets/uploads/page/Draft_Resource_Adequacy_Primer.pdf)

6

7

8   BNEF (2025a). <https://about.bnef.com/insights/clean-energy/how-pv-plus-storage-will-compete-with-gas-generation-in-the-u-s/>

9

10

11   BNEF (2025b). <https://about.bnef.com/insights/clean-energy/global-cost-of-renewables-to-continue-falling-in-2025-as-china-extends-manufacturing-lead-bloomberg/>

12

13

14   California Energy Commission (2025). [https://www.energy.ca.gov/news/2025-11/californias-battery-storage-fleet-continues-record-growth-strengthening-grid#:~:text=California%20has%20nearly%2017%2C000%20megawatts%20of%20battery,record%2Dbreaking%20heat%20and%20extreme%20weather%20without%20outages\\*\\*](https://www.energy.ca.gov/news/2025-11/californias-battery-storage-fleet-continues-record-growth-strengthening-grid#:~:text=California%20has%20nearly%2017%2C000%20megawatts%20of%20battery,record%2Dbreaking%20heat%20and%20extreme%20weather%20without%20outages**)

15

16

17

18

19   California Public Utilities Commission (2025). <https://www.cpuc.ca.gov/-/media/cpuc-website/divisions/energy-division/documents/resource-adequacy-homepage/resource-adequacy-compliance-materials/guides-and-resources/2026-ra-slice-of-day-filing-guide.pdf>

20

21

22

23   Clean Energy Canada (2023). A Renewables Powerhouse, <https://cleanenergycanada.org/report/a-renewables-powerhouse/>

24

25

26   Clean Energy Council (2021).  
<https://cleanenergycouncil.org.au/cec/media/background/resources/battery-storage-the-new-clean-peaker-report-2021.pdf>

27

28

29

30   CSIRO Gencost (2025). <https://www.csiro.au/en/research/technology-space/energy/Electricity-transition/GenCost>

31

32

33   Ember (2025). <https://ember-energy.org/latest-insights/how-cheap-is-battery-storage/#3-with-a-65-mwh-lcos-shifting-half-of-daily-solar->

34

35

36   Energy Storage News (2025a). <https://www.energy-storage.news/battery-storage-system-prices-continue-to-fall-sharply-bnef-and-ember-reports-find/>

37

38

39   Energy Storage News (2025b). <https://www.energy-storage.news/the-more-local-we-produce-the-better-evlo-on-tariffs/>

40

41

42   Energy Storage News (2024). <https://www.ess-news.com/2024/12/18/hagersville-battery-park-energy-storage-canada-financing/>

43

44

45   Energy Transitions Commission (2025). [https://www.energy-transitions.org/wp-content/uploads/2025/07/Power-Systems-Transformation\\_Main-report\\_vf.pdf](https://www.energy-transitions.org/wp-content/uploads/2025/07/Power-Systems-Transformation_Main-report_vf.pdf)

46

47

1 Ericson et al. (2022). Influence of hybridization on the capacity value of PV and battery resources,  
2 NREL, <https://docs.nrel.gov/docs/fy22osti/75864.pdf>

3

4 Energy Storage News (December 18 2024). <https://www.ess-news.com/2024/12/18/hagersville-battery-park-energy-storage-canada-financing/>

5

6 Energy Storage News (June 18 2025). <https://www.ess-news.com/2025/06/18/us-tender-alert-massachusetts-takes-steps-toward-40-gwh-energy-storage/>

7

8 Flyvbjerg, B., cited in Engineering News Record (2023). <https://www.enr.com/articles/55774-oxford-professors-latest-book-examines-roots-of-project-failure>

9

10 Global Affairs Canada (2025). <https://international.canada.ca/en/global-affairs/corporate/transparency/briefing-documents/parliamentary-committee/2024-10-21-ciit>

11

12 Lashitew, A (2025). <https://news.mcmaster.ca/analysis-canadas-tariff-wall-on-chinese-electric-vehicles-is-deepening-dependence-on-the-u-s/>

13

14 Gumber, A., Zana, R., Steffen, B., (2024). A global analysis of renewable energy project  
15 commissioning timelines, Applied Energy, Volume 358,  
16 <https://doi.org/10.1016/j.apenergy.2023.122563>

17

18 IEA (2025). <https://www.iea.org/reports/renewables-2025>

19

20 IESO (2024). <https://www.ieso.ca/-/media/Files/IESO/Document-Library/resource-adequacy/ieso-resource-adequacy-update-May2024.pdf>

21

22 IESO (2025). Ancillary Services, <https://www.ieso.ca/ancillary-services#:~:text=Certified%20black%20start%20facilities%20help%20system%20reliability,re%20Denergize%20other%20portions%20of%20the%20power%20system>.

23

24 Ipieca (2022). <https://www.ipieca.org/resources/energy-efficiency-compendium/open-cycle-gas-turbines-2022>

25

26 IRENA (2025). <https://www.irena.org/News/articles/2025/Aug/Battery-energy-storage-systems-key-to-renewable-power-supply-demand-gaps>

27

28 Kroposky, B. (2024). Introduction to Grid Forming Inverters,  
29 <https://docs.nrel.gov/docs/fy24osti/90256.pdf>

30

31 Lashitew, A (2025). <https://news.mcmaster.ca/analysis-canadas-tariff-wall-on-chinese-electric-vehicles-is-deepening-dependence-on-the-u-s/>

32

33 Lazard (June 2025). [https://www.lazard.com/media/5tlbhyla/lazards-lcoeplus-june-2025-\\_vf.pdf](https://www.lazard.com/media/5tlbhyla/lazards-lcoeplus-june-2025-_vf.pdf)

34

35 LFP Battery (2025). <https://www.lifepo4batteryshop.com/blogs/understanding-c-rate.html>

1 Massachusetts Department of Energy (2025a). Peak Potential: Load managements for an  
2 affordable net zero, <https://www.mass.gov/info-details/peak-potential-load-management-for-an-affordable-net-zero-grid>

4

5 Massachusetts Department of Energy (2025b). Technical potential of load management,  
6 <https://www.mass.gov/doc/e3-technical-potential-of-load-management-summary-slides/download>

8

9 Minnesota Public Utilities Commission (2022).  
10 <https://efiling.web.commerce.state.mn.us/documents/%7B202C2F80-0000-C11A-BA52-EC8AB5636CD4%7D/download?contentSequence=0&rowIndex=169>

12

13 Minnesota Public Utilities Commission (2023).  
14 <https://efiling.web.commerce.state.mn.us/documents/%7BD038968B-0000-CE1E-9643-CFF068E843FA%7D/download?contentSequence=0&rowIndex=442>

16

17 Modo Energy (2025a). <https://modoenergy.com/research/caiso-five-key-policy-market-design-initiatives-follow-2025-stakeholder-process-timeline-impact-battery-energy-storage>

19

20 Modo Energy (2025b). <https://modoenergy.com/research/en/nyiso-ancillary-service-beginners-guide-to-operations-battery-energy-storage-frequency-regulation-reserves>

22

23 Modo Energy (2025c). <https://modoenergy.com/research/en/caiso-california-iso-resource-adequacy-how-to-guide-generation-storage-must-offer-obligations-load-serving-entities-payments-explainer>

26

27 Natural Resources Canada (2025). <https://natural-resources.canada.ca/energy-efficiency/home-energy-efficiency/canada-greener-homes-initiative/greener-homes-initiative-progress-update-november-2024>

30

31 Natural Resources Canada (2025). <https://natural-resources.canada.ca/climate-change/sreps>

32

33 NB Power (2023). Integrated Resource Plan. <https://www.nbpower.com/media/1492472/2023-integrated-resource-plan-en.pdf>

35

36 NB Power (2024). Annual Report 2023-2024,  
37 <https://www2.gnb.ca/content/dam/gnb/Gateways/ABCs/Annual-reports1/2023-2024/NRED-NBPC-2023-2024-annual-report-E.pdf>

39

40 NERC (2025). Evaluating Resource Contributions for Reliability and Capacity Supply,  
41 [https://www.nerc.com/globalassets/our-work/reports/special-reports/elcc\\_report\\_september\\_2025.pdf](https://www.nerc.com/globalassets/our-work/reports/special-reports/elcc_report_september_2025.pdf)

43

44 NERC (May 2025). 2025 Summer reliability assessment,  
45 [https://www.nerc.com/globalassets/programs/rapa/ra/nerc\\_sra\\_2025.pdf](https://www.nerc.com/globalassets/programs/rapa/ra/nerc_sra_2025.pdf)

46

47 Northland Power (2025). <https://www.northlandpower.com/en/news/press-release/northland-power-secures-financing-to-advance-the-jurassic-battery-energy-storage-project-in-alberta.aspx>

48

1 Northland Power (2023). <https://www.northlandpower.com/en/news/press-release/northland-power-announces-commercial-operations-at-oneida-energy-storage-project-canadas-largest-bat.aspx#:~:text=The%20project%20was%20completed%20with,at%20financial%20close%20in%202023.>

2

3

4

5

6 NREL (2024). Annual Technology Baseline, <https://atb.nrel.gov/electricity/2024/technologies>

7

8 Parkinson, G., (2025). <https://reneweconomy.com.au/low-cost-iron-air-technology-to-feature-in-worlds-biggest-battery-project-in-us/>

9

10

11 Power and Telecom (2025). <https://powerandtelecom.ca/projects/skyview-2-battery-energy-storage-project-secures-contract-with-ieso/>

12

13

14 PV Magazine (2026). <https://www.pv-magazine.com/2026/01/02/battery-technology-outlook-for-2026-sharpens-beyond-lithium-ion/>

15

16

17 Redondo-Iglesias, E., Pelissier, S. (2022). On the efficiency of LFP Lithium-ion batteries, [https://www.researchgate.net/publication/366551786\\_On\\_the\\_Efficiency\\_of\\_LFP\\_Lithium-ion\\_Batteries](https://www.researchgate.net/publication/366551786_On_the_Efficiency_of_LFP_Lithium-ion_Batteries)

18

19

20

21 RSM Canada (December 10 2024). <https://rsmcanada.com/insights/economics/canadian-firms-in-an-era-of-a-higher-cost-of-capital.html>

22

23

24 Saint John Energy (2024). Annual Report 2023-2024, [https://sje-cms.s3.ca-central-1.amazonaws.com/SJE\\_Annual\\_Report\\_Spring2024\\_bf60b3c2fb.pdf](https://sje-cms.s3.ca-central-1.amazonaws.com/SJE_Annual_Report_Spring2024_bf60b3c2fb.pdf)

25

26

27 Saint John Energy (June 17 2025). <https://sjenergy.ca/about/news/saint-john-energy-announces-provinces-largest-solar-farm> and <https://zero30.ca/projects-products/#burchill>

28

29

30 SEIA (2025). <https://seia.org/state-solar-policy/maine-solar#:~:text=According%20to%20the%20SEIA%2C%20Maine%20has%20the,SEIA%20also%20has%20a%20National%20Solar%20Database>

31

32

33

34 Sidley (2025). [https://www.sidley.com/-/media/publications/california-approves-major-overhaul-of-battery-storage-om-standards.pdf%3Frev=752c6d3c03fa414e88a940a70a13fafa&sc\\_lang=en](https://www.sidley.com/-/media/publications/california-approves-major-overhaul-of-battery-storage-om-standards.pdf%3Frev=752c6d3c03fa414e88a940a70a13fafa&sc_lang=en)

35

36

37 Siemens Energy (2025). <https://www.siemens-energy.com/global/en/home/press-releases/two-become-one-siemens-energy-combines-two-technologies-to-stab.html>

38

39

40 Siemens PTI (2024). <https://www.lrl.mn.gov/docs/2024/mandated/240414.pdf>

41

42

43 Sim, L., Young, K. E. (2025). What impedes solar energy deployment? New evidence from power developers in the Arab Gulf States, *Energy for Sustainable Development*, Vol. 84, <https://doi.org/10.1016/j.esd.2024.101597>.

44

45 <https://www.sciencedirect.com/science/article/pii/S0973082624002230>

46

47

48 SPP (2022). <https://www.spp.org/documents/68930/2022%20elcc%20esr%20report.pdf>

1  
2 SPP (2023). <https://www.spp.org/documents/68930/2022%20elcc%20esr%20report.pdf>;  
3  
4 Statistics Canada (2025a).  
5 <https://oee.nrcan.gc.ca/corporate/statistics/neud/dpa/showTable.cfm?type=CP&sector=res&juri>  
6 [s=nb&rn=21&year=2022&page=0](#)  
7  
8 Statistics Canada (2025b). <https://www150.statcan.gc.ca/t1/tbl1/en/tv.action?pid=2010002501>  
9  
10 UK Government (2025).  
11 <https://assets.publishing.service.gov.uk/media/677bc80399c93b7286a396d6/clean-power-2030-action-plan-main-report.pdf>  
12  
13  
14 Uniper (2025). <https://www.uniper.energy/news/grid-stability-technology-without-the-need-to-generate-power-comes-into-operation-at-unipers-killingholme-site>  
15  
16 US Energy Information Administration (2025).  
17 [https://www.eia.gov/outlooks/aoe/electricity\\_generation/pdf/AEO2025\\_LCOE\\_report.pdf](https://www.eia.gov/outlooks/aoe/electricity_generation/pdf/AEO2025_LCOE_report.pdf)  
18  
19  
20 Vermont Legislative Services Committee (2025). <https://www.uvm.edu/d10-files/documents/2025-12/Financial-Features-of-Large-Scale-Solar-Array-Projects-in-Vermont.pdf>  
21  
22  
23 Wärtsila (2026). <https://www.wartsila.com/energy/energy-storage/technology/quantum-bess>  
24  
25 Wood Mackenzie (2025). <https://www.woodmac.com/press-releases/renewable-levelized-cost-of-electricity-competitiveness-reaches-new-milestone-across-global-markets-in-2025/>  
26